

BBJ-SEP

BBJ-SEP

BBJ-SEP

BBJ-SEP

BBJ-SEP

04-703 Warszawa, ul. Pożaryskiego 28
 tel. (+48 22) 812 69 38, fax (+48 22) 815 65 80
 e-mail: bbj@bbj-sep.com.pl

CERTIFICATE No. B/12/146/04

authorizing to mark products with the safety mark

Name and address of the certificate holder: ELEKTRA Sp. j.
 Włodzimierz Nyc, Witold Nyc
 02-674 Warszawa, ul. Marynarska 14

Name and address of the manufacturer: ELEKTRA Sp. j.
 Włodzimierz Nyc, Witold Nyc
 02-674 Warszawa, ul. Marynarska 14

Name of product: series heating cables with one or two XLPE insula
 conductors, with CU-screen and with PVC corrosion
 protection sheath

Type (variations): VC; VCS; VCD; VCSD;
 (type 800 IEC 20 XLPE 80/PVC 70 acc. to IEC 600800)

Principal ratings: rated voltage 300/500V, number of conductors 1 or 2;
 the resistance of heating conductor at 20°C from 0.05Ω
 operating surface temperature 70°C;

Classification symbol: 1123-6

Product meets the safety requirements as provided in: PN-IEC 800:1998

Test Report No. : TP-02.017; TP-01.061/2


Certification model: MODEL 5 ISO

Right to mark products from 2004-03-01 to 2007-02-28

is related only to samples with identical properties (parameters) as the sample (samples) presented and satisfying the aforesaid requirements.

Rights and duties of both parties resulting from this certificate are defined in an separate agreement.

Director



Piotr Gondek

BBJ-SEP

Warsaw, 2004-02-24

Translation of the Polish original

